



THE CORPORATION OF THE TOWNSHIP OF MUSKOKA LAKES

BOX 129 PORT CARLING, ONTARIO P0B 1J0

TEL: (705) 765-3156

FAX: (705) 765-3197

BLDG@TOWNSHIP.MUSKOKALAKES.ON.CA

**CERTIFICATE OF INSPECTION
RE: READINESS FOR OCCUPANCY**
Building Code Act, S.O. 1992, c23

PERMIT NUMBER 2003-0188

MAILING ADDRESS: PO BOX 339

OWNERS: [REDACTED]

PORT CARLING ON
P0B 1J0

ROLL NUMBER: 90 007 037 02 0000

TYPE OF BUILDING: 4F

LEGAL DESC: CON 10 PT LOT 14 90.78AC 514.30FR

TAKE NOTICE THAT THE ABOVE BUILDING:

Sewage system completed and ready for use

I, **SANDY BOS** CERTIFY THAT AN INSPECTION HAS BEEN MADE OF THE ABOVE NOTED BUILDING UNDER SECTION 11 OF THE BUILDING CODE ACT AND I HAVE DETERMINED THAT 0 OUTSTANDING WORK ORDERS EXIST.


ADDITIONAL COMMENTS:

THE SEWAGE SYSTEM INSTALLED SERVICES A <200 SQ. METRE DWELLING WITH 22.5 FIXTURE UNITS AND 4 BEDROOMS. THE SYSTEM CONSISTS OF A 4,500 LITRE CONCRETE SEPTIC TANK AND A 30 SQ. METRE FILTER BED. THE MAXIMUM DAILY DESIGN SEWAGE FLOW IS 2,250 LITRES/DAY.

NOTE: The land in the vicinity of the sewage system shall be maintained (free of deep rooting vegetation, trees, etc.) in a condition that will not cause damage to, or impair the functioning of, the sewage system.

DATE OF INSPECTION: 2003-10-01

SIGNATURE OF INSPECTOR:


2004-02-21.