

USE PERMIT FOR CLASS 4, 5, 6 SEWAGE SYSTEMS

APPLICATION NO. M-104-85

INSPECTION DETAILS	TIME 3:45 pm	DATE July 7/87	WEATHER overcast
REPRESENTING:	THE OWNER	THE INSTALLER Diane Brown	


1. Work authorized by the Certificate of Approval has been satisfactorily completed and includes:
- a) Septic tank/holding tank of working capacity of 850 Imp. Gals. constructed of steel  concrete  fibreglass  on site  or prefabricated  to serve \_\_\_\_\_ (no. of bedrooms or units).

MAKE AND MODEL, IF PREFABRICATED TANK Orilla Precast.

- b) Leaching bed of total 80 lineal feet of 3 inch diameter distribution pipe of Daymond Clarkson (type and product description e.g. manufacturer(s) and material of which pipe is made) laid in 4 runs and fed by gravity (gravity, siphon, pump).
- c) Proprietary Aerobic System: (Manufacturer) N/A (Model) \_\_\_\_\_
- d) Other details 12' x 22' 10" dms. 30' 20' x 4' 80' dms.

2. Location

- a) System components installed as shown on application supporting Certificate of Approval
- b) If located other than in (a) use space below for sketch and dimensions from permanent points of reference sufficient to facilitate future location of tank and leaching bed including orientation of pipe runs.



3. The following work remains to be completed:
- Backfill System and Complete
  - Stabilize All Sloped Surfaces
  - Finish Grading to Shed Run-off and Divert Water Around Leaching Bed
  - Other Topsoil tested

USE PERMIT		
Under Section 67 of the Environmental Protection Act, and subject to the provisions of the Act and Regulations a Permit is hereby issued to (Owner) <u>Woodend</u> for the use and operation of the Class <u>4r</u> sewage system constructed/installed/enlarged/extended/alterd pursuant to the Certificate of Approval issued under the above application number in accordance with the application and Certificate of Approval with any changes indicated above and located on Lot <u>32</u> Concession <u>2</u> Ward/Township/Municipality <u>Medora</u> Region/District/County <u>Muskoka</u> Plan No. _____ Sub-Lot No. _____		
INSPECTED-AND RECOMMENDED BY <u>[Signature]</u>	PERMIT ISSUED BY <u>[Signature]</u> DIRECTOR	DATE ISSUED <u>July 7/87</u>

Note: Section 64(a) of the Act provides that no change can be made to any building(s) or structure(s) in connection with which this sewage system is used, if the operation or effectiveness of the sewage system will or is likely to be affected by the change, unless a new Certificate of Approval is obtained.

Section 121 of the Act provides that an applicant for a permit may appeal a decision to refuse to issue a permit. Written notice of appeal must be forwarded to the Director (who refused to issue the permit) and to the Environmental Appeal Board, 1 St. Clair Avenue West, Toronto, Ontario, M4V 1K7 within 15 days of receipt of a permit.

WARNING: UNDER NO CIRCUMSTANCES SHOULD A HOMEOWNER ENTER A SEPTIC TANK. NOxious GASES WHICH ARE