


OCCUPANCY CERTIFICATE - SEWAGE SYSTEM FIELD INSPECTION SHEET

Date: Oct 9/01. File No.: _____
 Time: 8:11am. Inspector: S. Bos.
 Weather: overcast Installer: Self

1. Tank

- ☒ Manufacturer: Brooklin Orillia Wedco Other: _____
☐ Capacity (L/gal): 3600/800 4500/1000 Other: 3800L
☐ Outlet Connected to Header or Pump Chamber: _____

2. Sketch (show setbacks for both bed & tank)



MINIMUM SETBACK ALLOWANCES		
	Tank [m]	Bed [m]
Public		
Property		
Highway		
Water		
Electric		
Gas		
Drainage		
Other		

3. a) Filter Bed

- ☐ Required Filter Area: _____ m² Actual: L 20' m X W 12' m = A 22 m²
☐ Required Extended Contact Area: _____ m² Actual: L _____ m X W _____ m = A _____ m²
☐ # of Runs: (4) 5 6 Other: _____
☒ Run Separation: 1.2m max. allowed Actual: 36" 4.
☐ End Treatment: Capped Connected Neither _____
☐ Filter Quality: Sieve Analysis Provided: Yes No _____
☐ Quantity of Filter material (see filter sheet): _____
☐ Stone: OK No OK Type: Limestone Granite Quality 3/4 Other: _____
☐ Slope (max. 3:1): _____



THE CORPORATION OF THE TOWNSHIP OF MUSKOKA LAKES

BOX 129 PORT CARLING, ONTARIO P0B 1J0

TEL: (705) 765-3156

FAX: (705) 765-3197

BLDG@TOWNSHIP.MUSKOKALAKES.ON.CA

CERTIFICATE OF INSPECTION
RE: READINESS FOR OCCUPANCY
Building Code Act, S.O. 1992, c23

PERMIT NUMBER 2001-0770

OWNERS: 767916 ONTARIO INC

MAILING ADDRESS: C/O BERNARD LARKIN
BOX 279

PORT CARLING ON
P0B 1J0

ROLL NUMBER: 50 003 081 00 0000

TYPE OF BUILDING: SEWAGE

LEGAL DESC: CON 3 LOT 29 RP 35R5017 PART 1

TAKE NOTICE THAT THE ABOVE BUILDING:

sewage system completed and ready for use

I, **SANDY BOS** CERTIFY THAT AN INSPECTION HAS BEEN MADE OF THE ABOVE NOTED BUILDING UNDER SECTION 11 OF THE BUILDING CODE ACT AND I HAVE DETERMINED THAT NO OUTSTANDING WORK ORDERS EXIST.

ADDITIONAL COMMENTS:

THE SEWAGE SYSTEM REPLACED SERVICES A <200 SQ. METRE DWELLING WITH 3 BEDROOMS AND <20 FIXTURE UNITS. THE SYSTEM CONSISTS OF AN EXISTING 3,800 LITRE SEPTIC TANK AND A 22 SQ. METRE FILTER BED. THE MAXIMUM DAILY DESIGN FLOW IS 1,650 LITRES/DAY.

DATE OF INSPECTION: 2002-04-10

SIGNATURE OF INSPECTOR: