

USE PERMIT
FOR CLASS 4, 5, 6 SEWAGE SYSTEMS

APPLICATION NO.
00-42-84

INSPECTION DETAILS TIME 1:30 PM DATE MAY 21/86

WEATHER
OVERCAST

REPRESENTING:

THE OWNER
THE INSTALLER
BOB McNEIL

1. Work authorized by the Certificate of Approval has been satisfactorily completed and includes:

- a) Septic tank/holding tank of working capacity of 850 Imp. Gals. constructed of steel ☐ concrete ☒ fiberglass ☐ on site ☐ or prefabricated ☒ No serve 3 (no. of bedrooms or units).

MAKE AND MODEL, IF PREFABRICATED TANK ORILLIA LOW-BOY


- b) Teaching bed of total 172 lineal feet of 3 inch diameter distribution pipe of CANCON PVC (type and product description e.g. Canon CSA Approved PVC) laid in 4 runs and fed by gravity (gravity, siphon, pump).

c) Proprietary Aerobic System: (Manufacturer)

d) Other details Filter bed area approx 22m² (240 ft²) (Model)

2. Location

- a) System components installed as shown on application supporting Certificate of Approval ☐
b) If located other than in (a) use space below for sketch and dimensions from permanent points of reference sufficient to facilitate future location of tank and teaching bed including orientation of pipe runs.



3. The following work remains to be completed: -

- ☐ Backfill System and Complete ☐ Finish Grading to Shed Run-off and Divert Water Around Leaching Bed
☒ Stabilize All Sloped Surfaces ☒ Other Seed/sod bed area. Install sewage pump & connect all facilities.

Any Use Permit issued hereunder may be revoked if this work is not completed promptly to Provincial standards.

USE PERMIT

Under Section 59a of The Environmental Protection Act, 1971 and subject to the provisions of The Act and Regulations a Permit is hereby issued to (Owner) Howard Smith & John Curphey for the use and operation of the Class 4E sewage system constructed/installed/enlarged/extended/alterd pursuant to the Certificate of Approval issued under the above application number in accordance with the application and Certificate of Approval with any changes indicated above and located on Lot 28 Concession 8 Ward/Township/Municipality WOOD Region/District/County MUSKOKA Plan No. M-65 Sub-Lot No. 14

INSPECTED AND RECOMMENDED BY [Signature] PERMIT ISSUED BY [Signature] DATE ISSUED MAY 23/86

DIRECTOR

Note: Section 57(a) of The Act provides that no change can be made to any building(s) or structure(s) in connection with which this sewage system is used, if the operation or effectiveness of the sewage system will or is likely to be affected by the change, unless a new Certificate of Approval is obtained.
Section 78 of The Act provides that an applicant may appeal the imposition of terms and conditions by a Director on issuing a permit. Written notice of appeal must be forwarded to the Director and to the Environmental Appeal Board, 365 Bay Street, Suite 900, Toronto, Ont., M5H 2V3 within 15 days of receipt of the permit.